Indian Standard

SPECIFICATION FOR ARTIFICIAL LIGHTWEIGHT AGGREGATES FOR CONCRETE MASONRY UNITS

(First Reprint OCTOBER 1990)

UDC 666.972.125:693.54

© Copyright 1979

BUREAU OF INDIAN STANDARDS MANAK BHAVAN, 9 BAHADUR SHAH ZAFAR MARG NEW DELHI 110002

Indian Standard

SPECIFICATION FOR ARTIFICIAL LIGHTWEIGHT AGGREGATES FOR CONCRETE MASONRY UNITS

Cement and Concrete Sectional Committee, BDC 2

Chairman

Representing

DR H. C. VISVESVABAYA

Cement Research Institute of India, New Delhi

Members

STAN- Research, Designs & Standards Organization ADDITIONAL DIRECTOR. DARDS (B&S) (Ministry of Railways), Lucknow

STAN-DEPUTY DIRECTOR. DARDS (B&S) (Alternate)

Shri K, C. Aggarwal Hindustan Prefab Ltd. New Delhi

SHRI C. L. KASLIWAL (Alternate)

SHRIK, P. BANERJEE Larsen & Toubro Ltd, Bombay SHRI HARISH N. MALANI (Alternate)

SHRI R. N. BANSAL

Beas Designs Organization, Nangal Township

SHRI T. C. GARG (Alternate) DR N. S. BHAL

Structural Engineering Research Centre (CSIR). Roorkee Geological Survey of India, Calcutta

SHRIR. V. CHALAPATHI RAO SHRI S. ROY (Alternate)

CRIEF ENGINEER (DESIGNS) EXECUTIVE ENGINEER

(DESIGNS) III (Alternate)

Central Public Works Department, New Delhi

CHIEF ENGINEER (PROJECTS)

Irrigation Department, Government of Punjab, Chadigarh

DIRECTOR, IPRI (Alternate)
DIRECTOR (CSMRS)

DEPUTY DIRECTOR (CSMRS) (Alternate) National Test House, Calcutta

SHRI AMITABHA GHOSH SHRIE. K. RAMACHANDRAN (Alternate)

Central Water Commission, New Delhi

DR R. K. GHOSH

Central Road Research Institute (CSIR). New Delhi

SHRIY. R. PHULL (Alternate I) SHRI M. DINAKARAN (Alternate II)

DR R. K. GROSH Indian Roads Congress, New Delhi

SHRI B. R. GOVIND

Engineer-in-Chief's Branch, Army Headquarters, New Delhi

SHRI P. C. JAIN (Alternate)

(Continued on page 2)

Copyright 1979

BUREAU OF INDIAN STANDARDS

This publication is protected under the Indian Copyright Act (XIV of 1957) and reproduction in whole or in part by any means except with written permission of the publisher shall be deemed to be an infringement of copyright under the said Act.

```
( Continued from page 1 )
                                               Representing
         Members
                                              Asbestos Cement Products Ltd.
SHRI A. K. GUPTA
                                Hyderabad
                                    Hyderabad
                                The Associated Cement Companies Ltd, Bombay
DR R. R. HATTIANGADI
   SHRI P. J. JAGUS ( Alternate )
                                Engineering Research Laboratories, Hyderabad
DR IOBAL ALI
                                Directorate General of Supplies & Disposals,
SHRI M. T. KANSE
                                    New Delhi
                                 M. N. Dastur & Co ( Pvt ) Ltd, Calcutta
SHRI S. R. KULKARNI
                                The Institution of Engineers (India). Calcutta
SHRI S. K. LAHA
   SHRIB. T. UNWALLA ( Alternate )
DR MOHAN RAI
                                Central
                                         Building Research Institute (CSIR).
                                    Roorkee
   DR S. S. REHSI ( Alternate )
                                In personal capacity ('Ramanalaya' 11 First
SHRI K. K. NAMBIAR
                                    Crescent Park Road, Gandhinagar, Adyar, Madras)
                                National Buildings Organization, New Delhi
DR A. V. R. RAO
   SHRIK, S. SRINIVASAN ( Alternate )
                                Gammon India Ltd, Bombay
SHRI T. N. S. RAO
   SHRI S. R. PINHEIRO ( Alternate )
                                Cement Corporation of India Ltd. New Delhi
SHRI ARJUN RIJESINGHANI
   SHRIK, VITHAL RAO ( Alternate )
                                Central Board of Irrigation and Power, New Delhi
SECRETARY
   DEPUTY SECRETARY (I) ( Alternate )
                                Roads Wing (Ministry of Shipping and Transport)
SHRI N. SEN
   SHRI J. R. K. PRASAD ( Alternate )
                                The India Cements Ltd. Madras
SHRI K. A. SUBRAMANIAM
   SHRIP, S. RAMACHANDRAN ( Alternate )
                                Public
                                        Works
                                                 Department,
                                                               Government
                                                                              of
SUPERINTENDING ENGINEER
                                    Tamil Nadu, Madras
  ( Designs )
   EXECUTIVE
                      ENGINEER
     (SM & R Division) (Alternate)
                                Dalmia Cement ( Bharat ) Ltd, New Delhi
SHRI L. SWAROOP
   SHRI A. V. RAMANA ( Alternate )
                                The Concrete Association of India, Bombay
SHRI B. T. UNWALLA
   SHRI T. M. MENON ( Alternate )
SHRI D. AJITHA SIMHA,
                                Director General, ISI ( Ex-officio Member )
   Director (Civ Engg)
```

Secretary

SHRI M. N. NEELAKANDHAN Assistant Director (Civ Engg), ISI

Concrete Subcommittee, BDC 2:2

SHRI C. R. ALIMCHANDANI Stup Consultants India Ltd, Bombay
SHRI M. C. TANDON (Alternate)
SHRI D. CHAKRAVARTY Engineers India Ltd, New Delhi
DEPUTY DIRECTOR, STANDARDS Research, Designs and Standards Organization
(B&S)
ASSISTANT DIRECTOR, STANDARDS (M/C) (Alternate)

(Continued on page 7)

Indian Standard

SPECIFICATION FOR ARTIFICIAL LIGHTWEIGHT AGGREGATES FOR CONCRETE MASONRY UNITS

0. FOREWORD

- **0.1** This Indian Standard was adopted by the Indian Standards Institution on 22 March 1979, after the draft finalized by the Gement and Concrete Sectional Committee had been approved by the Civil Engineering Division Council.
- 0.2 One of the methods of producing lightweight concrete is by using lightweight aggregates. The essential characteristic of lightweight aggregate is its high porosity which results in a low apparent specific gravity. Some lightweight aggregates occur naturally and others are manufactured. This standard specifies the requirements of artificial lightweight aggregates. The lightweight aggregates covered in this standard are used for manufacture of concrete masonry units (see IS: 3590-1966*).
- **0.2.1** The detailed requirements of cinder aggregates which are also artificial lightweight aggregates used for manufacture of precast blocks, are given in IS: 2686-1977†.
- 0.3 For the purpose of deciding whether a particular requirement of this standard is complied with, the final value, observed or calculated, expressing the result of a test or analysis, shall be rounded off in accordance with IS: 2-1960‡. The number of significant places retained in the rounded off value should be the same as that of the specified value in this standard.

1. SCOPE

1.1 This standard covers the requirements of artificial lightweight aggregates, such as foamed blast furnace slag, bloated clay aggregate, sintered fly ash aggregate and cinder aggregate intended for use in concrete masonry units in which prime consideration is lightness in mass.

Rules for rounding off numerical values (revised).

^{*}Specification for load bearing lightweight concrete blocks.

[†]Specification for cinder aggregates for use in lime concrete (first revision).

2. GENERAL CHARACTERISTICS

- 2.1 General types of artificial lightweight aggregates covered by this standard are the following:
 - a) Aggregates prepared by expanding molten blast furnace slag in limited amount of water or jets of steam, by bloating of clays and shales at high temperature or by sintering of fly ash; and
 - b) Cinder aggregates conforming to Class C of IS: 2686-1977*.
- 2.2 The aggregates shall be composed, predominantly of lightweight cellular and granular inorganic material.

3. GRADING

3.1 The grading of the aggregate, that is, its particle size distribution as obtained by sieve analysis shall be as given in Table 1.

TABLE 1 GRADING REQUIREMENTS FOR LIGHTWEIGHT COMBINED AGGREGATES FOR CONCRETE MASONRY UNITS

| St. No. | Size Designation | Percentages (BY Mass) Passing IS Sieves | | | | | | |
|------------|---|---|-------------------------|--------|---------|---------|---------|----------------|
| | | 20 mm | 12-5 mm | 10 mm | 4·75 mm | 2·36 mm | 1·18 mm | 300 microns |
| (1) | (2) | (3) | (4) | (5) | (6) | (7) | (8) | (9) |
| i) | Fine aggregate (4.75 to 0 mm) | | · <u> </u> | 100 | 85-100 | _ | 40-80 | 10-35 |
| ii) | Coarse aggregate (12 5 to 4.75 mm) | 100 | 90 - 10 0 | 40-80 | 0-20 | 0-10 | _ | _ |
| | (10 to 2.36 mm) | | 100 | 80-100 | 5-40 | 0-20 | | |
| iii) | Combined fine and coarse aggregate (10 mm to 0) | | 100 | 90-100 | 65-90 | 35-65 | _ | 10-25 |

4. BULK DENSITY

- 4.1 The dry loose bulk density of combined aggregate shall not exceed 1 100 kg/m³.
- **4.2 Uniformity of Mass** The bulk density of successive supplies of lightweight aggregate shall not differ by more than 10 percent from that of the sample submitted for acceptance tests.

^{*}Specification for cinder aggregates for use in lime concrete (first revision).

5. DELETERIOUS SUBSTANCES

- 5.1 Lightweight aggregates shall not contain excessive amounts of deleterious substances, as determined by the limits described in 5.1.1 to 5.1.3.
- 5.1.1 Organic Impurities Lightweight aggregates, upon being subjected to the test for organic impurities, that produce a colour darker than the standard colour shall be rejected, unless it can be demonstrated that the discolouration is due to small quantities of materials not harmful to the concrete.
- 5.1.2 Clay Lumps The amount of clay lumps shall not exceed 2 percent by dry mass.
- 5.1.3 Loss on Ignition Loss on ignition of aggregates except cinder aggregates shall not exceed 4 percent by dry mass. For cinder aggregates, loss on ignition shall be as specified in IS: 2686-1977*.

6. CONCRETE MAKING PROPERTIES

- 6.1 Concrete specimens containing lightweight aggregate under test shall meet the requirements specified in 6.1.1 and 6.1.2.
- 6.1.1 Drying Shrinkage The drying shrinkage of concrete specimens prepared and tested in accordance with 7.7 shall not exceed 0:10 percent.
- **6.1.2** Sulphate Content The sulphate content of lightweight aggregate shall not be more than one percent when expressed as sulphuric anhydride (SO₃) by mass.

7. METHODS OF SAMPLING AND TEST FOR AGGREGATE PROPERTIES

- 7.1 Sampling The sampling of lightweight aggregates shall be done in accordance with IS: 2430-1969†.
- 7.2 Grading Grading of sample of lightweight aggregate shall be done in accordance with the provisions given in IS: 2386 (Part I)-1963‡.
- 7.3 Bulk Density (Loose) The aggregate shall be tested in oven-dry conditions according to the requirements given in 3 of IS: 2386 (Part III)-1963§.

†Methods for sampling of aggregates for concrete.

Methods of test for aggregates for concrete: Part I Particle size and shape.

^{*}Specification for cinder aggregates for use in lime concrete (first revision).

[§]Methods of test for aggregates for concrete: Part III Specific gravity, density, voids, absorption and bulking.

- 7.4 Orangic Impurities The aggregate shall be tested in accordance with IS: 2386 (Part II)-1963*.
- 7.5 Clay Lumps Clay lumps in aggregate shall be determined as described in IS: 2386 (Part II)-1963*.
- 7.6 Loss on Ignition Loss on ignition of the aggregate shall be determined by the method described in 4.2 of IS: 4032-1968†.
- 7.7 Drying Shrinkage The drying shrinkage of concrete shall be determined according to the method given in IS: 3590-1966.
- 7.8 Sulphate Content The sulphate content of sample shall be determined as specified in IS: 4032-1968†.

8. SUPPLIER'S CERTIFICATE AND COST OF TESTS

- 8.1 The supplier shall satisfy himself that the material complies with the requirements of this standard and, if requested, shall supply a certificate to this effect to the purchaser.
- **8.2** If the purchaser requires independent tests to be made, the sample for such tests shall be taken before or immediately after delivery, according to the option of the purchaser and the tests carried out in accordance with this standard and on the written instructions of the purchaser.
- 8.3 The supplier shall supply free of charge the material required for tests.
- 8.4 The cost of tests carried out under 8.2 shall be borne by:
 - a) the supplier, if the results show that the material does not comply with this standard; and
 - b) the purchaser, if the results show that the material complies with this standard.

^{*}Methods of test for aggregates for concrete: Part II Estimation of deleterious materials and organic impurities.

[†]Method of chemical analysis of hydraulic cement.

[±]Specification for load bearing lightweight concrete blocks.

(Continued from page 2)

Members

Representing

Engineering Research Laboratories, Hyderabad DIRECTOR DIRECTOR (C & MDD) Central Water Commission, New Delhi DEPUTY DIRECTOR (C & MDD) (Alternate)

Shri V. K. Ghanekar Structural Engineering Research Centre (CSIR). Roorkee

SHRI A. S. PRASADA RAO (Alternate)

Central Road Research Institute Dr R. K. Ghosh (CSIR). New Delhi

SHRI M. R. CHATTERJEE (Alternate)

SHRI V. K. GUPTA Engineer-in-Chief's Branch, Army Headquarters, New Delhi

SHRI S. V. TIGARE (Alternate) SHRI J. S. HINGORANI

Associated Consulting Services, Bombay SHRI A. P. REMEDIOS (Alternate)

The Associated Cement Companies Ltd, Bombay SHRI P. J. JAGUS SHRI M. R. VINAYAKA (Alternate)

SHRI G. C. MATHUR SHRI G. T. BHIDE (Alternate)

National Buildings Organization, New Delhi

SHRI K. K. NAMBIAR

personal capacity ('Ramanalaya' 11 First Crescent Park Road, Gandhinagar Adyar, Madras) Roads Wing (Ministry of Shipping and Transport)

SHRI N. S. RAMASWAMY SHRI R. P. SIKKA (Alternate) SHRI T. N. S. RAO

SUPERINTENDING ENGINEER.

Gammon India Ltd, Bombay

SHRIS. R. PINHEIRO (Alternate) SHRI M. P. GAJAPATHY RAU

Public Works and Housing Department, Bombay Central Public Works Department, New Delhi

DELHI CENTRAL CIRCLE No. 2 SHRIS. G. VAIDYA (Alternate)

Central Building Research Institute (CSIR), DR C. A. TANEJA Roorkee

SHRI B. S. GUPTA (Alternate) SHRI B. T. UNWALLA

The Concrete Association of India, Bombay

SHRIT. M. MENON (Alternate)

DR H. C. VISVESVARAYA Cement Research Institute of India, New Delhi DR A. K. MULLICK (Alternate)

BUREAU OF INDIAN STANDARDS

| Headquarters: | | | | | | | | |
|---|----------------------------------|--|--|--|--|--|--|--|
| Manak Bhavan, 9 Bahadur Shah Zafar Marg, NEW DELHI 110002 | | | | | | | | |
| | Manaksanstha to all Offices) | | | | | | | |
| Regional Offices: | Telephone | | | | | | | |
| Central: Manak Bhavan, 9 Bahadur Shah Zafar Marg, NEW DELHI 110002 | (331 01 31 }331 13 75 | | | | | | | |
| *Eastern : 1/14 C. I. T. Scheme VII M, V. I, P. Road, Maniktola, CALCUTTA 700054 | 36 24 99 | | | | | | | |
| Northern: SCO 445-446, Sector 35-C, CHANDIGARH 160036 | { 2 18 43 3 16 41 | | | | | | | |
| Southern: C. I. T. Campus, MADRAS 600113 | 41 24 42 41 25 19 41 29 16 | | | | | | | |
| †Western : Manakalaya, E9 MIDC, Marol, Andheri (East BOMBAY 400093 |), 6 32 92 95 | | | | | | | |
| Branch Offices: | | | | | | | | |
| 'Pushpak', Nurmohamed Shaikh Marg, Khanpur, AHMADABAD 380001 | 2 63 48 2 63 49 | | | | | | | |
| ‡Peenya Industrial Area 1st Stage, Bangalore Tumkur Ro BANGALORE 560058 | ad (38 49 55 38 49 56 | | | | | | | |
| Gangotri Complex, 5th Floor, Bhadbhada Road, T. T. Nag BHOPAL 462003 | ar, 6 67 16 | | | | | | | |
| Plot No. 82/83, Lewis Road, BHUBANESHWAR 751002 53/5 Ward No. 29, R.G. Barua Road, 5th Byelane, GUWAHATI 781003 | 5 36 27 3 31 77 | | | | | | | |
| 5-8-56C L. N. Gupta Marg (Nampally Station Road), HYDERABAD 500001 | 23 10 83 | | | | | | | |
| R14 Yudhister Marg, C Scheme, JAIPUR 302005 | { 6 34 71 6 98 32 | | | | | | | |
| 117/418 B Sarvodaya Nagar, KANPUR 208005 | 21 68 76 21 82 92 | | | | | | | |
| Patliputra Industrial Estate, PATNA 800013 T.C. No. 14/1421. University P.O., Palayam TRIVANDRUM 695035 | 6 23 05 | | | | | | | |
| Inspection Offices (With Sale Point): | • | | | | | | | |
| Pushpanjali, First Floor, 205-A West High Court Road, Shankar Nagar Square, NAGPUR 440010 | 2 51 71 | | | | | | | |
| Institution of Engineers (India) Building, 1332 Shivaji Na PUNE 411005 | gar, 5 24 35 | | | | | | | |

Sales Office in Calcutta is at 5 Chowringhee Approach, P. O. Princep 27 68 00 Street, Calcutta 700072

[†]Sales Office in Bombay is at Novelty Chambers, Grant Road, 89 65 28 Bombay 400007

[‡]Sales Office in Bangalore is at Unity Building, Narasimharaja Square, 22 36 71 Bangalore 560002